

PUBLIC NOTIFICATION
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
HAA5 VIOLATION AT The Heard County Water Authority Water System

Our community water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing to correct this situation. We routinely monitor for the presence of drinking water contaminants. We have been notified by the State that our water system exceeded the maximum contaminant levels (MCL) for the following:

Violation ID	Compliance Period	Site #	Analyte	Concentration	MCL
2024-22820	3Q2023 – 07/01/2023 – 09/30/2023	502	HAA5	0.072 mg/L	0.060 mg/L

What should I do?

There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What does this mean?

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What happened? What is being done?

We are working to minimize the formation of HAA5 while ensuring we maintain an adequate level of disinfectant. We have taken additional steps to change disinfectant levels, remove natural organic matter, and increased flushing of water lines to determine if our efforts have been effective.

For more information, please contact Matthew Dean at (706) 675-6435.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is provided by **Heard County Water Authority**
State Water System ID#: **GA1490000**
Date of public notice distributed: ____ 12/15/2023 ____